

Checklist for Self-Inspection Biosafety: Animal Facilities

Based on the „Checklisten für Inspektionen gemäss der Einschliessungsverordnung (ESV)“ of the FOEN

Information on self-inspection	
Date	
participants (names)	
inspected laboratories (buildings, room numbers, safety levels)	

relevant colors:

BSL1: white and green cases

BSL2: white, green and yellow cases

BSL3: white, green, yellow and orange cases

1. General Information

Nr.	Information on lab / group / institute	
1.1	department institute group	
1.2	BSO (name) Deputy-BSO (name)	
1.3	project leader (name)	
1.4	announced activities (ECOGEN-Nr., BSL) not yet announced activities	
1.5	ensuring 3rd party liability (only BSL 3)	
1.6	External users	

2. General Safety Measures

Nr.	safety measures	fulfilled		
		yes	no	?
2.1	Are standard operating procedures (SOPs) and rules of conduct available?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.2	Is there at least one nominated BSO?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.3	Are there washing and decontaminating facilities available for the employees?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.4	Are eyewash facilities available?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.5	Are the monitoring measures and the equipment adequately controlled and maintained?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.6	If required, is the presence of viable process organisms outside the primary physical barriers been tested?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.7	Are suitable storage facilities for potentially contaminated equipment and materials used?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.8	In case of leak / spill of organisms, are effective disinfectants and procedures provided?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

3. Good microbiological practice

Nr.	safety measures	fulfilled		
		yes	no	?
3.1	Are the doors and windows of the premises closed during work?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.2	Is eating, drinking, smoking, storage of food, snuffing or applying make-up in work areas banned?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.3	Is mouth-pipetting forbidden?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.4	Are syringes and needles use only when absolutely necessary?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.5	Are syringes and needles safely disposed of in a "sharps container"?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.6	Is ensured that no preventable aerosols are formed during work?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.7	Are hands carefully washed after each operation and when leaving the premises? Are hands disinfected after any contamination?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.8	Are the work areas tidy and clean?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.9	Are only the required materials and equipment kept in the lab?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.10	Are the work surfaces cleaned after work?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.11	Are stock materials stored in designated spaces or cabinets?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.12	Is the identity of the used microorganisms checked regularly?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.13	Does the interval of checking the organisms correlate with their hazard potential?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.14	Are the results of these checks evaluated?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.15	Are all employees working with GMO and pathogenic organisms instructed (before starting the work and at least once per year hereafter)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.16	Are inexperienced employees working in microbiology informed of possible dangers, guided and monitored?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.17	Will pests be dealt with (e.g. rodents, insects)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.18	Are animals forbidden in the lab?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

4. Additional safety measures (animal facilities)

4.1. Building

Nr.	safety measure	safety level			fulfilled		
		1	2	3	1	2	3
4.1.1	Is the work area separated?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.2	If there are windows, can they be opened?	Yes	Yes	No	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.3	Can the doors to the animal rooms be locked?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.4	Can the doors of the animal facility prevent an escape of animals?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.5	Are drains, etc. constructed in a way that prevents animals (rodents, insects, similar animals, etc.) from entering the animal facility?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.6	Are the animal rooms equipped with easily washable floors?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.7	Are the animal rooms equipped with easily washable walls?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.8	Are the junctions between floors and walls constructed in a way that allows easy cleaning?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.9	Is the work area sealed so that it can be fumigated?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.10	Are there biohazard warning signs at the entrance to the controlled area?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.11	Are devices that are outside the lab or in a BSL 1 area, but in which BSL 2 organisms with are handled (e.g. freezers) labeled with a biohazard warning sign?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.12	Is access to the work area restricted (by: access only with key / control card / authorized persons access list)?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.13	Is the entrance to the area only possible via an airlock room?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.14	Is there a (contact-free) hand-wash station and disinfectant in the airlock room?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Nr.	safety measure	safety level			fulfilled		
		1	2	3	1	2	3
4.1.15	Is there an observation window or other viewing point into the working area available?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.16	Are alarm systems for people working alone installed?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.17	Are there devices available to facilitate communication with people outside the work area?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.18	Is the work area (and airlock room) kept under constant negative pressure?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.19	Are the animal rooms ventilated sufficiently?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.20	Is a separate ventilation system installed?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.21	Is the working area ventilated with directed air?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.22	Is air circulation into other areas of the building prevented?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.1.23	In case of an incident, is an overpressure in the work area prevented by the special construction of the ventilation system?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.24	In the event of a failure in the negative pressure system is there an alarm system in place?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.25	Is the ventilation system connected to an emergency power supply?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.26	Can the ventilation system be operated externally (in case of fumigation)?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.27	Is the exhaust air HEPA filtered?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.28	Can the used HEPA filters be sterilized before being replaced, or can they be demounted without touching them, and afterwards being packed airtight and sterilized?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.29	Are all other facilities that need power and are important for the safety of others connected to an emergency power supply?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.1.30	Are there alarm systems (fire, failure of the heating system)?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

4.2. Equipment

Nr.	safety measure	safety level			fulfilled		
		1	2	3	1	2	3
4.2.1	Are the surfaces of benches resistant to acids, alkalis, solvents and disinfectants?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.2	Is the floor resistant to acids, alkalis, solvents and disinfectants?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.3	Is the work area provided with its own equipment?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.4	Is a microbiological safety cabinet available (if microorganisms are handled), and appropriately positioned and designed?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.5	Are the animals kept in suitable cages, stables or containers (species-appropriate, easy to clean, e.g. cages made from waterproof material)? ^(a)	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.6	Are there filters installed for isolated cages or isolated rooms?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.7	Are measures taken against aerosol formation? ^(b)	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.8	Is there an autoclave? Is the autoclave installed in the correct location? ^(c)	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.9	Are centrifuges with an aerosol-tight cover used (e.g. with O-ring)?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.10	Does the autoclave record time and temperature of each run?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.2.11	Are there shower facilities?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

(a) BSL 1: washable; BSL 2 und 3: suitable for decontamination

(b) BSL 1: avoid aerosol formation; BSL 2: minimize aerosol formation; BSL 3: prevent aerosol formation

(c) BSL 1: available; BSL 2: in the same building; BSL 3: in the laboratory

4.3. Organization

Nr.	safety measure	safety level			fulfilled		
		1	2	3	1	2	3
4.3.1	Are inspection and maintenance of the autoclave and other equipment performed on a regular basis?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2	Is the tightness of the centrifuge vessels checked?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.3	Are the centrifuge vessels closed while running?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.4	Are the people who enter the work area informed about the activities carried out in it?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.5	Is special clothing worn in the work area? ^(a)	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.6	Will clothing and Personal Protection Equipment that may be contaminated by microorganisms be disinfected if necessary?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.7	Are protective and normal clothing kept separately in an appropriate facility?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.8	Are gloves worn during work? ^(b)	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.9	Is skin contact with rDNA and microorganisms avoided?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.10	Are hands decontaminated and washed after handling animals, waste or after contamination?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.11	Are working areas disinfected regularly?	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.12	Are working areas disinfected after a spill?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.13	Are the animal facilities cleaned regularly?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.14	Are the cages disinfected after use?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.15	Are the sinks disinfected regularly?	No	Yes	yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.16	Are the microorganisms in drains, sinks, tubings and shower facilities inactivated?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.17	Are the carcasses sterilized in the lab before they are disposed of?	No	No	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.18	Werden Tierkadaver in einer bewilligten Verbrennungsanlage verbrannt?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

(a) BSL 1 and 2: Laboratory clothing / lab coat; BSL 3: Wear suitable protective clothing and shoes if necessary

(b) BSL 2: required when skin contact with the organisms cannot be avoided

Nr.	safety measure	safety level			fulfilled		
		1	2	3	1	2	3
4.3.19	Are the microorganisms in contaminated materials, waste and equipment inactivated? ^(a)	No	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.20	Is the waste that contains microorganisms collected separately?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.21	Are carcasses cooled while they are stored?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.22	Are syringes and needles safely disposed of in a "Sharps container"?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.23	Are the different types of waste labeled (type of waste, Biohazard signs at level 2, etc.)	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.24	Is the internal transport of organisms, material which contains organisms and waste properly performed (closed, leak- and shatter-proof container)?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.25	Is the external transport of organisms, material which contains organisms and waste performed according to the ADR / SDR regulations (closed, leak- and shatter-proof container)?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.26	Are the organisms stored safely in the laboratory?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.27	Can it be avoided that the stored organisms get into the waste water system (e.g. in case of a power failure)?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.28	Are male and female animals kept separately in order to avoid contamination by reproduction (except if reproduction is part of the studies)?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.29	Can the animals be identified easily? (e.g. with insert as additional markers)?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.30	Are food and tobacco stored out of reach of the animals?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.31	Are only the animals needed for the studies allowed in the animal facilities?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.32	Are measures against vermins, insects and rodents taken, if necessary?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

(a) BSL 1: harmless disposal

Nr.	safety measure	safety level			fulfilled		
		1	2	3	1	2	3
4.3.33	Is there a rule stating that the project leader and the BSO must be notified immediately in case of an injury?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.34	Do all employees know this rule?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.3.35	Is the protective clothing work only within the work area and removed before leaving said area?	Yes	Yes	Yes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ETH Zürich
 Safety, Security, Health and Environment (SSHE)
 Section CABS

Phone: +41 44 632 30 30
 cabs@eth.ch
 www.sicherheit.ethz.ch →
 Status: 27.06.2016